PAVUS, a.s.
AUTHORIZED BODY 216
NOTIFIED BODY 1391
ACCREDITED CERTIFICATION BODY
FOR PRODUCTS CERTIFICATION No 3041

Branch: **FIRE TESTING LABORATORY**
VESELÍ NAD LUŽNICÍ
Čtvrť J. Hybeše 879
CZ 391 81 Veselí nad Lužnicí
Czech Republic

Address:
Prosecká 412/74, 190 00 Praha 9 – Prosek
Phone: +420 286 019 587 Fax: +420 286 019 590
Mail to: mail@pavus.cz, http://www.pavus.cz

Phone: +420 381 477 418
Fax: +420 381 477 419
Mail to: veseli@pavus.cz

REACTION TO FIRE CLASSIFICATION REPORT

Subject of classification: *Floor coverings according to ČSN EN 13501-1+A1:2010, cl. 12*

Identification number: ***PK1-02-18-004-E-0***

Name and type of element: *TACTILE PATHS Inside - ruber (wheels, grooves)*

Sponsor: **DIZAJNBIRO-TAKTIL, Vladan Marković PR, PRIBOJ**
Ul. Rabrenovački put b.b.
31330 Priboj
Srbija

Issuing organization: *PAVUS, a.s.*
Authorized body AO 216
Notified body 1391
Accredited certification body for products certification No. 3041
– Accreditation issued by Czech Accreditation Institute, Public Service
– Certificate of Accreditation No. 762/2017
Prosecká 412/74
190 00 PRAHA 9
Order No Z210170389

Date of issue: *2018-03-09*

Copies in total: *4*

Copy number: *1*

Pages in total: *3*

1 INTRODUCTION

1.1 This Classification Report defines the classification assigned to the given product *TACTILE PATHS Inside - ruber (wheels, grooves)* in accordance with the procedures given in ČSN EN 13501-1+A1:2010 Fire classification of construction products and building elements – Part 1: Classification using test data from reaction to fire test.

1.2 This classification report consists of 3 pages and may be only used or reproduced in its entirety

2 DETAILS OF CLASSIFIED PRODUCT

2.1 Generally

The product – *TACTILE PATHS Inside - ruber (wheels, grooves)* – is intended as flooring.

2.2 Product description

Manufacturer:	DIZAJNBIRO-TAKTIL, Vladan Marković PR, PRIBOJ Ul. Rabrenovački put b.b. 31330 Priboj Srbija
Mass per unit area:	6.25 kg/m^2
Thickness:	5 mm

3 TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

3.1 Test reports

Name of laboratory Address Accreditation No.	Name of sponsor	Report ref. no. Date of issue	Test method and date Field of application rules and date
PAVUS, a.s. *Veselí nad Lužnicí* *AZL No 1026*	*DIZAJNBIRO-TAKTIL, Vladan Marković PR, PRIBOJ* *Ul. Rabrenovački put b.b.* *31330 Priboj* *Srbija*	*Pr-18-1.028* *2018-03-07*	*ČSN EN ISO 9239-1:2010* *ČSN EN 13238:2010*
		Pr-18-1.027 *2018-02-13*	*ČSN EN ISO 11925-2:2011*

3.2 Test results

Test method according to	Parameter	Number of tests	Results	
			Continuous parameter - mean	Compliance with parameters
ČSN EN ISO 9239-1	*critical heat flux CF (kW/ m^2)*	*3*	*10.3*	*$B_{fl} \geq 8.0$*
	integral of smoke obscuration s (%·min)		*629*	*$s1 \leq 750$*
ČSN EN ISO 11925-2 surface exposition	*flame spread F_s (mm)*	*6*	*0*	*≤ 150 mm up to 20 s*

4 CLASSIFICATION AND FIELD OF APPLICATION

4.1 Classification references

This classification has been carried out in accordance with ČSN EN 13501-1+A1:2010.

4.2 Classification

The product – *TACTILE PATHS Inside - rubber (wheels, grooves)* – in relation to its reaction to fire behaviour is classified:

Reaction to fire classification: B_{fl} - s1

4.3 Field of application

This classification applies for the following product parameters:

the product must be the same as the tested specimen.

This classification applies for the following end use applications:

the product is intended for floorings for substrates of reaction to fire class A1 and A2-s1 with density greater than 1,350 kg/m^3.

5 LIMITATIONS

This classification document does not represent type approval or certification of the product.

This classification is valid, unless the conditions, under which it was issued, have been changed. The sponsor may request the issuing authority to review the influence of changes to the classification validity.

Elaborated by:

Lenka SOBOTOVÁ
Fire Testing Laboratory

PAVUS, a.s.
Autorizovaná osoba AO 216
Pobočka
391 81 Veselí nad Lužnicí

Checked by:

Vladimír BENEŠ
Fire Testing Laboratory

PAVUS, a.s.
Autorizovaná osoba AO 216
Pobočka
391 81 Veselí nad Lužnicí

Approved by:

Jaroslav DUFEK

AKREDITOVANÝ CERTIFIKAČNÍ ORGÁN č. 3041 PRO CERTIFIKACI VÝROBKŮ
PAVUS
PAVUS, a.s.